

Date: 12/11/2025

Project: Forest View Bus Lane
Owner: Lansing School District

Location: Lansing, MI

A/E #: 2616.09

ADDENDUM NO. 02

SPECIAL NOTE:

The Notice to Bidders, Instructions to Bidders, General Conditions of the Contract for Construction, Supplementary Conditions of the Contract for Construction, and all modifications and previously issued Contract Documentation are a part of this Addendum.

SCOPE OF WORK:

The following items are changes, additions, deletions, clarifications and/or errors and omissions in plans & specifications and shall be considered by each Bidder in making up and submitting their proposal. All items shall be considered a part of the Contract Documents.

NOTICE TO ALL BIDDERS:

All Bidders shall take note of all items covered by this Addendum. Each Bidder shall review the total scope of his responsibilities with respect to his contract work and his interface with the work of others, as well as his required interface with their work.

INCLUDED:

RFI #9:

What are the two watermain sizes in the road that the contractor would need to connect the hydrant to and cross with the storm sewer? The drawings/specs are calling out CL54 for the watermain, but LBWL spec is pressure class 350 ductile. Please advise what class ductile is required.

The topo survey shows a 6" and 10" watermain running down the length of the street. To our knowledge, the hydrant would likely be connected to the 10". However, there should be an existing stub already to connect to, so that there is no need to tap the 10" watermain for the hydrant. The hydrant lead should be 6".

Please use CL-54 ductile iron pipe for all new watermain. CL-54 ductile iron also meets the pressure class 350 requirement.

END OF ADDENDUM - NO ATTACHMENTS.